



THE LEADER IN RESOURCE RECOVERY

## Pollutant Monitoring Results Water Monitoring

Licensee Name:

Environmental Protection Licence Number:

Facility Address:

A copy of the full licence can be found on the POEO Public Register <http://www.epa.nsw.gov.au/prpoeoapp/>

*Disclaimer - Monitoring data contained in this document is made available as required by Section 66(6) of the Protection of the Environment Operations Act 1997 and in accordance with the requirements issued in writing by the Environment Protection Authority. To the best of SITA's knowledge, the data in this table is correct, except where specifically noted. The information and data in this table must not be published elsewhere by any means without prior consent from SITA Australia. For more details on publication of pollution monitoring data refer to the NSW EPA Website [www.epa.nsw.gov.au](http://www.epa.nsw.gov.au)*

Date Monitoring Obtained	Sampling Point	No. of times measured during month	Pollutant	Monitoring Frequency Required by licence	Min Value	Mean Value	Median Value	Max Value	Unit	If Applicable Pollutant limit as per licence	Exceedance (Y/N) or NA	Comments
15/10/2014	1	1	Ammonia	Special Frequency	0.68	0.68	0.68	0.68	mg/L	0.9	No	
15/10/2014	1	1	pH	Special Frequency	7.96	7.96	7.96	7.96	pH	6.5 - 8.5	No	
15/10/2014	1	1	Total Suspended Solids	Special Frequency	8	8	8	8	mg/L	50	No	