



## Pollutant Monitoring Results

Date monitoring received: \_\_\_\_\_

Date published: \_\_\_\_\_

THE LEADER IN RESOURCE RECOVERY

Licensee Name: Port Stephens Waste Management Group Pty Ltd.

Environmental Protection Licence Number: 12556

Facility Address: 330 Newline Road, Raymond Terrace, NSW

A copy of the full licence can be found on the POEO Public Register <http://www.environment.nsw.gov.au/prpoeoapp/>

Disclaimer - Monitoring data contained in this document is made available as required by Protection of the Environment Operations Act 1997 and in accordance with the requirements of the Environmental Protection Authority. To the best of SITA's knowledge, the data in this table is specifically noted. The information and data in this table must not be published elsewhere without consent from SITA Australia. For more details on publication of pollution monitoring data Website [www.epa.nsw.gov.au](http://www.epa.nsw.gov.au)

Monitoring/ Sampling Date	Sampling Point	Pollutant	Monitoring Frequency Required by licence	Min Value	Mean Value	Median Value	Max Value	Unit	Exceedance (Y/N) or NA	Comments
8/10/2015	EPL POINT 1	Alkalinity (as CaCO3)	Quarterly	290	290	290	290	mg/L	NA	
8/10/2015	EPL POINT 1	Ammonia	Quarterly	120	120	120	120	µg/L	NA	
8/10/2015	EPL POINT 1	Calcium	Quarterly	83	83	83	83	mg/L	NA	
8/10/2015	EPL POINT 1	Chloride	Quarterly	140	140	140	140	mg/L	NA	
8/10/2015	EPL POINT 1	Chlorinated Volatile Compounds	Quarterly	ND	ND	ND	ND	mg/L	NA	ND = Below laboratory limit of reporting for multiple compounds
8/10/2015	EPL POINT 1	Conductivity	Quarterly	1000	1000	1000	1000	µS / cm	NA	
8/10/2015	EPL POINT 1	Fluoride	Quarterly	<0.5	<0.5	<0.5	<0.5	mg/L	NA	
8/10/2015	EPL POINT 1	Iron	Quarterly	0.54	0.54	0.54	0.54	mg/L	NA	
8/10/2015	EPL POINT 1	Magnesium	Quarterly	24	24	24	24	mg/L	NA	
8/10/2015	EPL POINT 1	Manganese	Quarterly	1.1	1.1	1.1	1.1	mg/L	NA	
8/10/2015	EPL POINT 1	Nitrate	Quarterly	<0.02	<0.02	<0.02	<0.02	mg/L	NA	
8/10/2015	EPL POINT 1	Organochlorine Pesticides	Quarterly	ND	ND	ND	ND	µg/L	NA	ND = Below laboratory limit of reporting for multiple compounds
8/10/2015	EPL POINT 1	pH	Quarterly	7.9	7.9	7.9	7.9	pH units	NA	
8/10/2015	EPL POINT 1	Potassium	Quarterly	35	35	35	35	mg/L	NA	
8/10/2015	EPL POINT 1	Sodium	Quarterly	70	70	70	70	mg/L	NA	
8/10/2015	EPL POINT 1	Standing Water Level	Quarterly	NA	NA	NA	NA	mAHd	NA	
8/10/2015	EPL POINT 1	Sulfate	Quarterly	13	13	13	13	mg/L	NA	
8/10/2015	EPL POINT 1	Total Phenolics	Quarterly	<50	<50	<50	<50	µg/L	NA	
8/10/2015	EPL POINT 1	Total Organic Carbon	Quarterly	52	52	52	52	mg/L	NA	

